

Himachal Pradesh
Jal Shakti Vibhag

No-:AE/JSV/SDS/Sanitary Report /2026- 1213-14

Dated- 23-02-26


To

The Principal,
New Millennium International School Ladwara ,
Tehsil.Shahpur Distt.Kangra H.P.


Subject-: Regarding Safe Drinking Water and Sanitary Condition Certificate.

Kindly refer to your office letter No. 0016/2026-27 Dated 18-02-2026 for safe drinking water and sanitary certificate. Accoringly the report of water examination is sent to your office.

In this matter it is also suggested the testing of water should be done regularly and cleaning of water tanks used for storage of water should also be done four times in a year and proper S.O.P for sanitation should be maintained


Assistant Engineer
Jal Shakti Sub Division
Shahpur

Copy forwarded to the Executive Engineer, Jal Shakti Division Shahpur for information please.


Assistant Engineer
Jal Shakti Sub Division
Shahpur

HIMACHAL PRADESH
JAL SHAKTI VIBHAG

REPORT OF PHYSICAL CHEMICAL & BACTERIOLOGICAL
EXAMINATION OF WATER SAMPLE

Lab Ref No. SDLS/24/2025-26

Dated: 23 Feb 2026

Block: Rait

Sub Division: Shahpur

Tehsil: Shahpur

Gram Panchayat: Manjgran Ladwara

Name of Source and Scheme: Hand Pump (New Millennium International School Ladwara)

Date & Time of collection: 20 Feb 2026, 13:40 PM


Date & Time of Receipt at Laboratory: 20 Feb 2026, 14:15 PM

Date & Time of Commencing: 20 Feb 2026, 14:25 PM

PHYSICAL EXAMINATION			
Name of Parameter	Acceptable Limit	Permissible limit	Result
Colour (Hazen scale units)	5 Max	15 Max	5 HU
Odour (Qualitative)	Agreeable	Agreeable	Agreeable
Taste	Agreeable	Agreeable	Agreeable
PH	6.5 to 8.5	No Relaxation	7.72
TDS	500 mg/l	2000 mg/l	174
Turbidity	1 NTU	5 NTU	0
Temperature (°C)			23.5°C
CHEMICAL EXAMINATION			
Total Alkalinity	200 mg/l	600 mg/l	200
Total Hardness	200 mg/l	600 mg/l	192
Calcium	75 mg/l	200 mg/l	62.4
Magnesium	30 mg/l	100 mg/l	8.7
Chloride	250 mg/l	1000 mg/l	22.7
Iron	1.0 mg/l	No Relaxation	0.07
Fluoride	1.0 mg/l	1.5 mg/l	0
Nitrate	45 mg/l	No Relaxation	0.34
Sulphate	200 mg/l	400 mg/l	1.6
Residual Chlorine	0.2 mg/l	1 mg/l	0
BACTERIOLOGICAL EXAMINATION			
Total Coliforms	Nil	Nil	Nil
E-Coli	Nil	Nil	--



Tested by
Assistant Chemist
Water Testing Laboratory



Assistant Engineer
Jal Shakti Sub-Division
Shahpur

Annexure C

No: AE / JSV / SDS / 2026 : 1213-14

Dated: 23-02-26

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 0007/2026

Dated: 12th Feb 2026

It is certified that an inspection team headed by SANTOSH KUMAR KAUSHAL

(Name of Officers with designation) from JE JSV SECTION PATALPHED

inspected the New Millennium International School Ladwara

(Name & Address of the school) on 23-02-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. SDS/24/2025-26 dated 23-02-2026

of Jal Shakti Water Testing Lab Shahpur (PHED Lab) certified that


the NEW MILLENNIUM INTERNATIONAL SCHOOL, LADWARA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 22-02-2027


Assistant Engineer
Jal Shakti Sub-Division
Shahpur

Signature with Seal:

Name

Designation


Name & Address of the Office / Department :

Mohammed Razak

Assistant Engineer

Jal Shakti Vibhag
Subdivision Shahpur

To

 JE JSV
Rajol

NEW MILLENNIUM INTERNATIONAL
SCHOOL, LADWARA, PO. - LADWARA

(Name & Address of the Institution) SHAHPUR
DIST - KANGRA HP
176208

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies